



Ref. Certif. No.

SE-113259

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Low-voltage switchgear and controlgear –
Part 3: Switch-disconnector

Name and address of the applicant

Zhejiang GEYA Electrical Co., Ltd.
Wenzhou Bridge Industrial Zone, Beibaixiang Town,
Yueqing City, Zhejiang Province, China 325603

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Same as applicant

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

Ue= 230/240V~(1P), 400/415V~ (2P, 3P, 4P), 50/60Hz
Ie= 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A
Icw= 1500A/1s, Icm= 3000A, Ui= 500V, Uimp= 6kV,
Cat. AC-22A

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

GYH8

Additional information (if necessary may also be
reported on page 2)☐ Additional Information on page 2A sample of the product was tested and found
to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which
forms part of this Certificate

231100077SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 02 February, 2024

Signature:

Anneli Averland Johansson