



Reference No. SE-S-2400142

Low-voltage switchgear and controlgear - Part 3: Switch-disconnector

Type designation: GYH8

Certificate holder: Zhejiang GEYA Electrical Co., Ltd.

Wenzhou Bridge Indstrial Zone, Beibaixiang Town, Yueqing City, Zhejiang Province, China 325603

The product complies with

the standard(s):

EN IEC 60947-3:2021

Date of expiry: 02 February, 2029

EU Directive information: According to the principle of presumption of conformity, this certificate

constitutes support for an EU Declaration of Conformity to the Low

Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 02 February, 2024

Anneli Averland Johansson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 1 of 2



APPENDIX:

Reference No. SE-S-2400142

Technical Data:

Type designation GYH8

Rated voltage (V) 230/240V~(1P), 400/415V~ (2P, 3P, 4P) Rated current (A) 16, 20, 25, 32, 40, 50, 63, 80, 100, 125

Frequency (Hz) 50/60 IP-Class IP20

Poles No. 1P, 2P, 3P, 4P Trademark

Test Report 231100077SHA-001

Product information Icw= 1500A, 1s, Icm= 3000A

Ui= 500V, Uimp=6kV, Cat. AC-22A

Manufacturing Sites: Zhejiang GEYA Electrical Co.,Ltd

Wenzhou Bridge Indstrial Zone, Beibaixiang Town, Yueqing City, Zhejiang Province, China 325603

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 02 February, 2024

Anneli Averland Johansson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 2 of 2