

中国认可
国际互认
检测
TESTING
CNAS L0116



TEST REPORT

REPORT NO. 25133Y30777Y

NAME OF SAMPLE Intelligent Circuit Breaker

MODEL GWS9-W

CUSTOMER ZHEJIANG GEYA ELECTRICAL CO., LTD.

MANUFACTURER ZHEJIANG GEYA ELECTRICAL CO., LTD.

TEST CATEGORY Entrusted Test

ZHEJIANG FANGYUAN TEST GROUP CO., LTD.
ZHEJIANG FANGYUAN ELECTRICAL EQUIPMENT TESTING CO.,LTD.
NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)

声 明

一、本实验室保证检测的公正性、独立性和诚实性，对报告的内容负责，报告中由委托方提供的信息的真实性由委托方负责。

二、本实验室出具的 CA 认证报告可通过扫描报告封面二维码或登录网址：<http://www.fydqjc.ltd:51036/#/search/pdfVerify> 上传完整版报告以查询真伪；纸质版报告未盖本实验室红色检验检测专用章、骑缝章无效；纸质版报告复印件未重新加盖本实验室红色检验检测专用章、骑缝章无效。

三、本报告无编制、审核、批准人签字无效；本报告涂改无效。

四、本实验室接受的送检样品，其代表性和真实性由委托方负责。本实验室对委托方提供的样品及相关技术资料保密。

五、本实验室不负责抽样时，本报告的检测数据和结果只对收到的样品负责。委托方若对本报告有异议，应及时向本实验室提出。政府行政管理部门下达的指令性任务，被检方对抽检结果有异议时，应按政府行政管理部门文件规定及国家相关法律、法规规定进行。

六、本报告中包含与规范或标准的符合性声明时，除特别约定、规范或标准有明确规定外，本实验室根据 IEC 导则第 115 号（IEC Guide 115:2023）4.3.3 条和 4.3.4 条考虑测量不确定度并做出符合性判定。

七、本报告各页均为报告不可分割之部分，未完整使用本报告全文由此造成的任何不良后果，本实验室不负相应的法律责任。

DECLARATION

1. Our laboratory guarantees impartiality, independence and honesty of inspection, and is responsible for the content of report. The customer is responsible for the information they provide.
2. The CA certification test report can be checked authenticity by scanning the QR code which is on test report cover or entering the website: <http://www.fydqjc.ltd:51036/#/search/pdfVerify> to upload the whole test report. The paper test report is invalid without the red special inspection stamp and paging seal of our laboratory. The paper copy of test report is invalid without the red special inspection stamp and paging seal of our laboratory.
3. The test report is invalid without signatures of the compiler, reviewer and authorized personnel. The test report is invalid if altered.
4. The customer is responsible for the representation and authenticity of the sample(s) they provide. Our laboratory keeps confidential of the sample(s) and related technical data provided by the customer.
5. The test results shown in this report is only applicable for the sample(s) received when our laboratory has not been responsible for the sampling stage. If there is any dissent of the report, the entrusting party shall notify our laboratory timely. For the mandatory inspection given by governmental administration departments, any dissent about the sample being tested or test results on the report should be dealt with in accordance with national regulations.
6. When a statement of conformity to a specification or standard is provided in the test report, the statement is made with measurement uncertainty accounted according to clause 4.3.3 and clause 4.3.4 of IEC GUIDE 115:2023, unless otherwise specified in special agreements, standards or specifications.
7. All the pages of the report are integral parts of the report. Our laboratory will not be responsible for any undesirable consequences caused by using separate page(s) of the report.

浙江方圆电气设备检测有限公司

地址：嘉兴市广穹路 400 号

邮编：314001 网址：www.fydqjc.cn

联系方式：

低压元件部：

0573-82077822、82077990（强制性认证检测、自愿性认证检测）

0573-82077811、82077511（委托检测、国际认证检测）

E-mail: fangyuantest_dy@163.com

低压成套部：

0573-82099578（强制性认证检测、自愿性认证检测）

0573-82077898（委托检测、国际认证检测）

E-mail: fangyuantest_ct@163.com

高压电器部：0573-82077919、82077099

新能源电器部：0573-82077355

智能电器部：0573-82077855

电磁兼容部：0573-82077600

防爆电器部：0573-82077233

避雷器与绝缘子部：0573-82079633

环境检测部：0573-82077277

计量中心：0573-82077033

E-mail: fangyuantest_hv@163.com

E-mail: fangyuantest_xny@163.com

E-mail: fangyuantest_zn@163.com

E-mail: fangyuantest_emc@163.com

E-mail: fangyuantest_ex@163.com

E-mail: fangyuantest_blq@163.com

E-mail: fangyuantest_hjjc@163.com

E-mail: fangyuantest_mc@163.com

NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)
TEST REPORT

Product	Intelligent Circuit Breaker	Test Category	Entrusted test
Model	GWS9-W	Trademark	/
Rated current	5(40)A	Rated voltage	AC240V
Technical parameter	UC1	Serial No.	/
Client	ZHEJIANG GEYA ELECTRICAL CO., LTD.	Address	WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN 325603 YUEQING, ZHEJIANG - CHINA
Manufacturer	ZHEJIANG GEYA ELECTRICAL CO., LTD.	Address	WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN 325603 YUEQING, ZHEJIANG - CHINA
Date of Manufacture	/	Sample(s) Deliverer	ZHEJIANG GEYA ELECTRICAL CO., LTD.
Receiving Number of Sample(s)	5 pcs	Receiving Date of Sample(s)	2025-04-29
Test Requirements	IEC 62055-31: 2022 Electricity metering – Payment systems –Part 31: Particular requirements – Static payment meters for active energy(classes 0,5, 1 and 2), IEC 60947-1:2014 Low-voltage switchgear and controlgear-Part 1: General rules		
Decision Criteria	IEC 62055-31: 2022 Electricity metering – Payment systems –Part 31: Particular requirements – Static payment meters for active energy(classes 0,5, 1 and 2), IEC 60947-1:2014 Low-voltage switchgear and controlgear-Part 1: General rules		
Description and Condition of Sample(s)	Be fit for test		
Test Date	2025-05-12 to 2025-08-21	Test location	No. 400 Guangqiong Road, Jiaxing City, Zhejiang, China
Test Summary	The entrusted samples have been tested according to IEC 62055-31: 2022 Electricity metering – Payment systems –Part 31: Particular requirements – Static payment meters for active energy(classes 0,5, 1 and 2), IEC 60947-1:2014 Low-voltage switchgear and controlgear-Part 1: General rules. See page 11 for detailed. The inspection results of the inspected items all meet the requirements of the standard (Decision Criteria). Test Seal Date of Approval: 2025-08-22		
Remarks	The client claims that, Rated voltage: AC240V, Rated current: 5(40)A, Utilization category: UC1.		

Approved by


Verified by

Test by

Compose

TEST REPORT

Photo and Nameplate of the Inspected Sample(s)



TEST REPORT

EMC test installation photos

Electrostatic discharges



Radiated radio-frequency electromagnetic fields




TEST REPORT

EMC test installation photos

Electrical fast transients/bursts (EFT/B)



Surges



TEST REPORT

EMC test installation photos

Conducted disturbances induced by radio-frequency fields



Voltage dips and interruptions



TEST REPORT

EMC test installation photos


Emission




TEST REPORT

EMC Connection diagram of the device under test

Electrostatic discharges




Radiated radio-frequency electromagnetic fields




TEST REPORT

EMC Connection diagram of the device under test

Electrical fast transients/bursts (EFT/B)




Surges




TEST REPORT

EMC Connection diagram of the device under test

Conducted disturbances induced by radio-frequency fields




Voltage dips and interruptions



TEST REPORT

EMC Connection diagram of the device under test



Other Explanation of the Test Report

/

TEST REPORT

Series Number	Test Case	Clause of standard	Serial No. of samples	Verdict
1	Pre-conditioning	IEC 62055-31: 2022 Annex C	1#	P
2	Electrical endurance	IEC 62055-31: 2022 Annex C	1#	P
3	Minimum switched current	IEC 62055-31: 2022 Annex C	1#	P
4	Power consumption in current circuits	IEC 62055-31: 2022 7.7	1#	P
5	Dielectric strength	IEC 62055-31: 2022 Annex C	1#	P
6	Pre-conditioning	IEC 62055-31: 2022 Annex C	2#	P
7	Short-circuit current carrying capacity Test1	IEC 62055-31: 2022 Annex C	2#	P
8	Minimum switched current	IEC 62055-31: 2022 Annex C	2#	P
9	Power consumption in current circuits	IEC 62055-31: 2022 7.7	2#	P
10	Dielectric strength	IEC 62055-31: 2022 Annex C	2#	P
11	Pre-conditioning	IEC 62055-31: 2022 Annex C	3#	P
12	Short-circuit current carrying capacity Test2	IEC 62055-31: 2022 Annex C	3#	P
13	Minimum switched current	IEC 62055-31: 2022 Annex C	3#	P
14	Power consumption in current circuits	IEC 62055-31: 2022 7.7	3#	P
15	Dielectric strength	IEC 62055-31: 2022 Annex C	3#	P
16	Pre-conditioning	IEC 62055-31: 2022 Annex C	4#	P
17	Line to load voltage surge withstand	IEC 62055-31: 2022 Annex C	4#	P
18	Fault current making capacity	IEC 62055-31: 2022 Annex C	4#	P
19	Minimum switched current	IEC 62055-31: 2022 Annex C	4#	P
20	Power consumption in current circuits	IEC 62055-31: 2022 7.7	4#	P
21	Dielectric strength	IEC 62055-31: 2022 Annex C	4#	P
22	Tests for EMC	IEC 60947-1:2014 8.4	5#	P
	(Blank below)			

Note 1.Possible test case verdicts:

- test case does not apply to the test object: N/A
- test object does meet the requirement: P (Pass)
- test object does not meet the requirement: F (Fail)
- test data provided without decision of compliance: Test data

Note 2.Serial No. of samples in this page and in the text 1#,2#,3#... is: 25133Y30777-1#,25133Y30777-2#,25133Y30777-3#...

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		1#	
IEC 62055-31: 2022 Annex C	Pre-conditioning		P
	Test voltage(r.m.s.)(V): $240_{-5}^{+5}\%$	246	
	Test current(r.m.s.)(A): $40_{-0}^{+5}\%$	40.5	
	$\cos\varphi$: $1.0_{-0.05}^0$	1.00	
	Conductor($\text{mm}^2 \times \text{m}$): 10×1	10×1	
	Number of operating cycles:3	3	
	Make time(s):5	5	
	Break time(s):5	5	
	Control voltage(V): /	/	
	The sample shall operate normally.	operate normally	
IEC 62055-31: 2022 Annex C	Electrical endurance		P
	Make and break: a sequence		
	Test voltage(r.m.s.)(V): $240_{-5}^{+5}\%$	246	
	Test current(r.m.s.)(A): $40_{-0}^{+5}\%$	40.5	
	$\cos\varphi$: $1.0_{-0.05}^0$	1.00	
	Number of operating cycles: 5000	5000	
	Make time(s): 10	10	
	Break time(s): 20	20	
	b sequence		
	Test voltage(r.m.s.)(V): $240_{-5}^{+5}\%$	246	
	Test current(r.m.s.)(A): $40_{-0}^{+5}\%$	40.2	
	$\cos\varphi$: 0.5 ± 0.05	0.50	
	Number of operating cycles: 5000	5000	
	Make time(s): 10	10	
	Break time(s): 20	20	
	Conductor($\text{mm}^2 \times \text{m}$): 10×1	10×1	
	Control voltage(V): /	/	
	Acceptance criteria		
	There is no welding or failure to close;	No signs	
	Excite the coil and it works normally.	Complied	
	Serial No. of oscillograms	S250777901~S250777912	

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		1#	
IEC 62055-31: 2022 Annex C	Minimum switched current Test voltage(r.m.s.)(V): $240_{-5}^{+5}\%$ Test current(r.m.s.)(A): $0.02_{-0}^{+5}\%$ $\cos\varphi$: $1.0_{-0.05}^0$ Number of operating cycles: 10 Make time(s): 10 Break time(s): 20 Conductor($\text{mm}^2 \times \text{m}$): 10×1 Control voltage(V): / Test current shall successfully conduct each time the contacts are in the closed position; Test current shall successfully break each time the contacts are in the open position.	246 0.02 1.00 10 10 20 10×1 / Complied Complied	P
IEC 62055-31: 2022 7.7	Power consumption in current circuits Test voltage(V): $240_{-5}^{+5}\%$ Test current(A): $40_{-0}^{+5}\%$ Conductor($\text{mm}^2 \times \text{m}$): 10×1 Measurement of power consumption: Test position: main circuit Incoming terminal –outgoing terminal Voltage-drop (mV): Power consumption(VA): $\leq 0.08\% U_e I_n$: 7.68	240 40.0 10×1 L~L 89.3 3.57	P

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		1#	
IEC 62055-31: 2022 Annex C	Dielectric strength 1). Impulse withstand voltage test Ambient temperature: °C Impulse voltage: In the open position(kV): $2.00^{+3}_{-3}\%$ In the closed position(kV): $2.00^{+3}_{-3}\%$ Impulse voltage wave: 1.2/50μs Interval(s): ≥3 Test times: 10times for the positive and negative polarity each. Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure; 2). Power frequency withstand voltage test Ambient temperature: °C Test voltage: In the open position(kV): $1.00^{+3}_{-3}\%$ In the closed position(kV): $1.00^{+3}_{-3}\%$ Time of applying voltage(min): 1 Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure; The leakage current shall be recorded: Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure;	24.2°C 2.01 2.01 10 10/10 No unintentional disruptive discharges No unintentional disruptive discharges 24.2°C 1.00 1.00 1 No flashover or puncture No flashover or puncture 3.90μA <1μA	P

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		2#	
IEC 62055-31: 2022 Annex C	Pre-conditioning		P
	Test voltage(r.m.s.)(V): $240_{-5}^{+5}\%$	246	
	Test current(r.m.s.)(A): $40_0^{+5}\%$	40.5	
	cosφ: $1.0_{-0.05}^0$	1.00	
	Conductor(mm ² ×m): 10×1	10×1	
	Number of operating cycles:3	3	
	Make time(s):5	5	
	Break time(s):5	5	
	Control voltage(V): /	/	
	The sample shall operate normally.	operate normally	
IEC 62055-31: 2022 Annex C	Short-circuit current carrying capacity Test1		P
	Test voltage(r.m.s.)(V): $1.15 \times 240_{-5}^{+5}\%$	278	
	Test current(r.m.s.)(kA): $3_0^{+5}\%$	3.08	
	cosφ: 0.85~0.90	0.88	
	Control voltage(V): /	/	
	Conductor(mm ² ×m): 10×1	10×1	
	Electrical angle: 0°	See the oscillogram for details	
	Duration(ms): one half cycle	11.4(max)	
	Test sequence: O ₁ -t ₁ -O ₂ -t ₂ -O ₃		
	Interval(min): ≥ 1	1	
	I _p max (kA)	4.27	
	I ² t max (kA ² s)	93.6	
	Acceptance criteria:		
	Welding and burning of contacts are allowed;	No signs	
	There shall be no signs of burning or smoking of the enclosure and the conductors;	No signs	
	The surroundings of the payment meter shall not be endangered.	No	
	Serial No. of the oscillogram of the prospective current:	Y250777001	
	Serial No. of the oscillograms:	S250777001~S250777003	

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		2#	
IEC 62055-31: 2022 Annex C	Minimum switched current Test voltage(r.m.s.)(V): $240_{-5}^{+5}\%$ Test current(r.m.s.)(A): $0.02_{-0}^{+5}\%$ $\cos\varphi$: $1.0_{-0.05}^0$ Number of operating cycles: 10 Make time(s): 10 Break time(s): 20 Conductor($\text{mm}^2 \times \text{m}$): 10×1 Control voltage(V): / Test current shall successfully conduct each time the contacts are in the closed position; Test current shall successfully break each time the contacts are in the open position.	246 0.02 1.00 10 10 20 10×1 / Complied Complied	P
IEC 62055-31: 2022 7.7	Power consumption in current circuits Test voltage(V): $240_{-5}^{+5}\%$ Test current(A): $40_{-0}^{+5}\%$ Conductor($\text{mm}^2 \times \text{m}$): 10×1 Measurement of power consumption: Test position: main circuit Incoming terminal –outgoing terminal Voltage-drop (mV): Power consumption(VA): $\leq 0.08\%U_e I_n$: 7.68	240 40.0 10×1 L~L 75.9 3.04	P

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		2#	
IEC 62055-31: 2022 Annex C	Dielectric strength 1). Impulse withstand voltage test Ambient temperature: °C Impulse voltage: In the open position(kV): $2.00^{+3}_{-3}\%$ In the closed position(kV): $2.00^{+3}_{-3}\%$ Impulse voltage wave: 1.2/50μs Interval(s): ≥3 Test times: 10times for the positive and negative polarity each. Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure; 2). Power frequency withstand voltage test Ambient temperature: °C Test voltage: In the open position(kV): $1.00^{+3}_{-3}\%$ In the closed position(kV): $1.00^{+3}_{-3}\%$ Time of applying voltage(min): 1 Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure; The leakage current shall be recorded: Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure;	24.2°C 2.00 2.00 10 10/10 No unintentional disruptive discharges No unintentional disruptive discharges 24.2°C 1.00 1.00 1 No flashover or puncture No flashover or puncture 3.97μA <1μA	P

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		3#	
IEC 62055-31: 2022 Annex C	Pre-conditioning Test voltage(r.m.s.)(V): $240_{-5}^{+5} \%$ Test current(r.m.s.)(A): $40_{-0}^{+5} \%$ $\cos\phi$: $1.0_{-0.05}^0$ Conductor($\text{mm}^2 \times \text{m}$): 10×1 Number of operating cycles:3 Make time(s):5 Break time(s):5 Control voltage(V): / The sample shall operate normally.	246 40.5 1.00 10×1 3 5 5 / operate normally	P
IEC 62055-31: 2022 Annex C	Short-circuit current carrying capacity Test 2 Test voltage(r.m.s.)(V): $1.15 \times 240_{-5}^{+5} \%$ Test current(r.m.s.)(kV): $1.5_{-0}^{+5} \%$ $\cos\phi$: 0.93~0.98 Control voltage(V): / Conductor($\text{mm}^2 \times \text{m}$): 10×1 Make time(ms):one half cycle Test sequence:O I_p max (kA) I^2t max (kA^2s) Acceptance criteria: There shall be no signs of sticking or welding of contacts; There shall be no signs of burning or smoking of the enclosure and the conductors; The surroundings of the payment meter shall not be endangered. Cooling the sample for more than 5 min after the test, the sample shall operate normally when applying the control voltage. Serial No. of the oscillogram of the prospective current: Serial No. of the oscillograms:	278 1.52 0.97 / 10×1 10.7 2.11 22.5 No signs No signs No Complied Y250777002 S250777101	P

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		3#	
IEC 62055-31: 2022 Annex C	Minimum switched current Test voltage(r.m.s.)(V): $240_{-5}^{+5}\%$ Test current(r.m.s.)(A): $0.02_{-0}^{+5}\%$ $\cos\varphi$: $1.0_{-0.05}^0$ Number of operating cycles: 10 Make time(s): 10 Break time(s): 20 Conductor($\text{mm}^2 \times \text{m}$): 10×1 Control voltage(V): / Test current shall successfully conduct each time the contacts are in the closed position; Test current shall successfully break each time the contacts are in the open position.	246 0.02 1.00 10 10 20 10×1 / Complied Complied	P
IEC 62055-31: 2022 7.7	Power consumption in current circuits Test voltage(V): $240_{-5}^{+5}\%$ Test current(A): $40_{-0}^{+5}\%$ Conductor($\text{mm}^2 \times \text{m}$): 10×1 Measurement of power consumption: Test position: main circuit Incoming terminal –outgoing terminal Voltage-drop (mV): Power consumption(VA): $\leq 0.08\%U_e I_n$: 7.68	240 40.0 10×1 L~L 77.6 3.10	P

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		3#	
IEC 62055-31: 2022 Annex C	Dielectric strength 1). Impulse withstand voltage test Ambient temperature: °C Impulse voltage: In the open position(kV): $2.00^{+3}_{-3}\%$ In the closed position(kV): $2.00^{+3}_{-3}\%$ Impulse voltage wave: 1.2/50μs Interval(s): ≥3 Test times: 10times for the positive and negative polarity each. Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure; 2). Power frequency withstand voltage test Ambient temperature: °C Test voltage: In the open position(kV): $1.00^{+3}_{-3}\%$ In the closed position(kV): $1.00^{+3}_{-3}\%$ Time of applying voltage(min): 1 Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure; The leakage current shall be recorded: Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure;	24.2 °C 2.00 2.00 10 10/10 No unintentional disruptive discharges No unintentional disruptive discharges 24.2 °C 1.00 1.00 1 No flashover or puncture No flashover or puncture 3.61μA <1μA	P

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		4#	
IEC 62055-31: 2022 Annex C	Pre-conditioning Test voltage(r.m.s.)(V): $240^{+5}_{-5}\%$ Test current(r.m.s.)(A): $40^{+5}_{-5}\%$ $\cos\varphi$: $1.0^{+0}_{-0.05}$ Conductor($\text{mm}^2 \times \text{m}$): 10×1 Number of operating cycles:3 Make time(s):5 Break time(s):5 Control voltage(V): / The sample shall operate normally.	246 40.5 1.00 10×1 3 5 5 / operate normally	P
IEC 62055-31: 2022 Annex C	Line to load voltage surge withstand Ambient temperature: $^{\circ}\text{C}$ Impulse voltage wave: $1.2/50\mu\text{s}$ Test voltage: measured data(kV) Interval:same polarity 60s, opposite polarity 60s Test times: Positive and negative poles: 5 times each Applied position: Apply $1^{+3}_{-3}\%$ kV, $2^{+3}_{-3}\%$ kV, $3^{+3}_{-3}\%$ kV, $4^{+3}_{-3}\%$ kV to $12^{+3}_{-3}\%$ kV between product contacts,and record the breakdown voltage between product contacts during the test It is permitted for flashover and disruptive discharge to occur during the test, there shall be no permanent damage to any part of the payment meter.	24.2 $^{\circ}\text{C}$ 60s 5/5 L ₁ 6.11kV Breakdown Pass	P

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		4#	
IEC 62055-31: 2022 Annex C	Fault current making capacity Test voltage(r.m.s.)(V): $1.15 \times 240^{+5}_{-5} \%$ Test current(r.m.s.) (kA): $1.5^{+5}_{-5} \%$ $\cos\phi$: 0.93~0.98 Control voltage(V): / Conductor(mm ² ×m): 10×1 Test sequence: 3 times Interval(min): ≥ 1 I_p max (kA) I^2t max (kA ² s) Duration: max (ms) Arcing time: max (ms) Acceptance criteria: 1) There shall be no signs of sticking or welding of contacts; 2) There shall be no signs of burning or smoking of the enclosure and the conductors; 3) The surroundings of the payment meter shall not be endangered; Serial No. of the oscillogram of the prospective current: Serial No. of the oscillograms:	278 1.52 0.97 / 10×1 3 1 2.09 22.1 10.7 / No signs No signs No Y250777002 S250777201~S250777203	P

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		4#	
IEC 62055-31: 2022 Annex C	Minimum switched current Test voltage(r.m.s.)(V): $240_{-5}^{+5}\%$ Test current(r.m.s.)(A): $0.02_{-0}^{+5}\%$ $\cos\varphi$: $1.0_{-0.05}^0$ Number of operating cycles: 10 Make time(s): 10 Break time(s): 20 Conductor($\text{mm}^2 \times \text{m}$): 10×1 Control voltage(V): / Test current shall successfully conduct each time the contacts are in the closed position; Test current shall successfully break each time the contacts are in the open position.	246 0.02 1.00 10 10 20 10×1 / Complied Complied	P
IEC 62055-31: 2022 7.7	Power consumption in current circuits Test voltage(V): $240_{-5}^{+5}\%$ Test current(A): $40_{-0}^{+5}\%$ Conductor($\text{mm}^2 \times \text{m}$): 10×1 Measurement of power consumption: Test position: main circuit Incoming terminal –outgoing terminal Voltage-drop (mV): Power consumption(VA): $\leq 0.08\%U_e I_n$: 7.68	240 40.0 10×1 L~L 72.5 2.90	P

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		4#	
IEC 62055-31: 2022 Annex C	Dielectric strength 1). Impulse withstand voltage test Ambient temperature: °C Impulse voltage: In the open position(kV): $2.00^{+3}_{-3}\%$ In the closed position(kV): $2.00^{+3}_{-3}\%$ Impulse voltage wave: 1.2/50μs Interval(s): ≥3 Test times: 10times for the positive and negative polarity each. Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure; 2). Power frequency withstand voltage test Ambient temperature: °C Test voltage: In the open position(kV): $1.00^{+3}_{-3}\%$ In the closed position(kV): $1.00^{+3}_{-3}\%$ Time of applying voltage(min): 1 Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure; The leakage current shall be recorded: Applied position: In the open position: Between the supply incoming terminal and the outgoing terminal; In the closed position: Between the supply incoming terminals connected together and the metal foil in contact with the outer surface of the enclosure;	24.2°C 2.00 2.00 10 10/10 No unintentional disruptive discharges No unintentional disruptive discharges 24.2°C 1.00 1.00 1 No flashover or puncture No flashover or puncture 3.73μA <1μA	P

TEST REPORT

Clause	Testing cases and requirements	Test results or observations	Verdict
		5#	
IEC 60947-1:2014 8.4 8.4.1.2.2	Tests for EMC		P
	Electrostatic discharges		
	Air discharges on non conductive accessible parts: $\pm 8\text{kV}$ Contact discharges on conductive accessible parts: $\pm 6\text{kV}$ Indirect discharges on the enclosure: $\pm 6\text{kV}$ The test shall be repeated 10 times at each measuring point, with a minimum time interval of 1s between pulses. It shall comply with performance criterion B	8kV(Shell, shell seam) 6kV(nut bolt) 6kV(HCP、VCP) Complied Complied Note: After the test, the test sample can be normally closed and opened through the software terminal control.	
8.4.1.2.3	Radiated radio-frequency electromagnetic fields Polarization direction: horizontal, vertical It shall comply with performance criterion A 1. Frequency range(MHz):80~1000 RF interference field strength(V/m): 10 2. Frequency range(MHz):1400~2700 RF interference field strength(V/m): 3 Actual dwell time (s):	Horizontal, vertical Complied 80~1000 10 1400~2700 3 1.0 Uncertainty:U=2.32dB,k=2 Note: After the test, the test sample can be normally closed and opened through the software terminal control.	
8.4.1.2.4	Electrical fast transients/bursts (EFT/B) (5/50ns) Test level (kV): 4 Repetition frequency(kHz): 5 Test time(min):1 Test position:Power line It shall comply with performance criterion A	4 5 1 Power line Complied	

TEST REPORT


Clause	Testing cases and requirements	Test results or observations	Verdict
		5#	
8.4.1.2.5	Surges (1.2/50μs~8/20μs) Test level: 2kV Test position: Pulses with both positive and negative polarity shall be applied, the phase angles being 0°, 90°, and 270° A series of 5 pulses is applied for each polarity and each phase angel the interval between two pulses being approximately 1min. It shall comply with performance criterion B	2kV(difference mode) L₁-N(difference mode) 5 times for each polarity and each phase angel 1 times per minute Complied Note: After the test, the test sample can be normally closed and opened through the software terminal control.	
	Test level: 4kV Test position: Pulses with both positive and negative polarity shall be applied, the phase angles being 0°, 90°, and 270° A series of 5 pulses is applied for each polarity and each phase angel the interval between two pulses being approximately 1min. It shall comply with performance criterion B	4kV(common mode) L₁-PE(common mode) N-PE(common mode) 5 times for each polarity and each phase angel 1 times per minute Complied Note: After the test, the test sample can be normally closed and opened through the software terminal control.	
8.4.1.2.6	Conducted disturbances induced by radio-frequency fields Test level(V):10 Frequency range(MHz):0.15~80 Test position: It shall comply with performance criterion A Actual dwell time (s):	10 0.15~80 Power line Complied 1.0 Note: After the test, the test sample can be normally closed and opened through the software terminal control.	


TEST REPORT


Clause	Testing cases and requirements	Test results or observations	Verdict
		5#	
8.4.1.2.8	Voltage dips and interruptions: Voltage dips test: Test level:(0%,0%,40%,70%,80%)×U _T V Duration:0.5T,1T,10T,25T,250T The phase angles tested are 0° and 180° respectively It shall comply with performance criterion B interruptions test: Test level: 0%,×U _T V Duration:250T It shall comply with performance criterion B	Complied	
		Complied	
		Note: After the test, the test sample can be normally closed and opened through the software terminal control.	


TEST REPORT


Clause	Testing cases and requirements		Test results or observations	Verdict		
			5#			
8.4.2	Emission		Complied			
	The test results shall meet the requirements of Environment B (Group 1).					
	Frequency range (MHz)	Quasi peak limits:				
		Quasi peak: dB(μV)			average value: dB(μV)	
	0.15~0.5	66 Decreasing linearly with logarithm of frequency to 56			56 Decreasing linearly with logarithm of frequency to 46	
	0.5~5	56			46	
	5~30	60			50	
	See attached drawings for details:				CE25133Y3077701~ CE25133Y3077702 Qp Uncertainty:U=3.0dB, k=2 AV Uncertainty:U=3.0dB, k=2	
	The test results shall meet the requirements of Environment B (Group 1).				Complied	
	Frequency range (MHz)	Quasi peak limits: dB(μV/m)				
	30 ~ 230	40 Quasi peak *				
	230 ~ 1000	47 Quasi peak *				
	*Measure 3m away from the sample		RE25133Y3077701 Uncertainty:U=3.8dB,k=2			
	See attached drawings for details:					






























Final Result

--- N Phase ---

No.	Frequency [MHz]	Reading QP [dB(μV)]	Reading AV [dB(μV)]	c.f [dB]	Result QP [dB(μV)]	Result AV [dB(μV)]	Limit QP [dB(μV)]	Limit AV [dB(μV)]	Margin QP [dB]	Margin AV [dB]	Remark
1	0.37899	41.8	24.2	10.3	52.1	34.5	58.3	48.3	6.2	13.8	
2	0.4749	40.6	24.6	10.3	50.9	34.9	56.4	46.4	5.5	11.5	





MAIN TEST EQUIPMENT LIST

No.	Name	Type	Equipment No.	Valid date	Use (√)
1	Data acquisition system	CRONOS-PL3	8489CA10A	2026-03-10	√
2	Temperature and humidity recorder	ZDR-F20	8339CB08A	2025-08-22	√
3	Torque driver	RTD500CN	9242DB22B	2026-07-04	√
4	Totaling Counter	DHC9J-J	8527DB12B	2026-07-06	√
5	Dual Display Digital Multimeter	GDM-8245	8427CB09A	2025-11-05	√
6	Temprature changeable quickly test box	WGDF405	8305DA07A	2026-05-04	√
7	Clamp electric meter	376	8854CA19A	2026-06-02	√
8	Stop Watch	ST4610-2	8088CB07B	2026-07-10	√
9	Thermo-hygro-barograph	DSR-THP	8962CB20B	2026-07-07	√
10	Torque Driver	50RTD	8938DB20B	2025-11-12	√
11	Data acquisition system	SYNERGY	8451CA10A	2025-12-24	√
12	Power frequency withstand voltage device	TOS5051A	8447CA10A	2025-09-01	√
13	Hygro-Thermometer	ZDR-F20	8337CB08A	2026-06-02	√
14	Impulse voltage tester	GC-20B	8759CA17A	2026-03-09	√
15	AC / DC digital milliammeter	HG2850	8481CB10B	2026-05-22	√
16	Digital multimeter	8845A	8446CA10A	2025-11-11	√
17	Data acquisition system	Saturn System	9600CA23A	2025-10-21	√
18	Digimatic calipers	(0~150) mm	8732CB15B	2025-10-22	√
19	Torque driver	RTD500CN	9243DB22B	2026-07-04	√
20	Data logger for Temperature and Humidity	DSR-TH	9831CB24B	2025-08-29	√
21	Multifunction timer	YS-318	7096CB25B	2026-03-18	√
22	ESD Generator	EMS61000-2A	8849DA19A	2026-02-20	√

MAIN TEST EQUIPMENT LIST

No.	Name	Type	Equipment No.	Valid date	Use (√)
23	Digital temperature and humidity atmospheric pressure gauge	testo622	9698CB23B	2025-08-29	√
24	Signal Source	N5171B	8963DA20A	2025-06-11	√
25	Power Meter	4242	8602CA12A	2025-07-31	√
26	RF SELECTOR	NS4900	8603CA12A	2025-07-31	√
27	Power Amplifier	AS0860-50	8964DA20A	2025-10-24	√
28	Power Amplifier	NTWPA-00810 200	8983DA20A	2025-07-31	√
29	3m Semi-Anechoic Chamber	SAC-3M	8699DA12A	2027-08-17	√
30	Directional Coupler	C6021-10	8613CA12A	2025-07-31	√
31	ELECTRIC FIELD PROBE	EP600	8614CA12A	2025-11-04	√
32	Grouped Pulse Generator	EMS61000-4A	8848DA19A	2026-02-10	√
33	Lightning surge generator	EMS61000-5A	8784CA18A	2025-10-16	√
34	Conducted Radiation Immunity Test System	NSG 4070	8618CA12A	2025-07-31	√
35	Attenuator	ATN 6050	8619CA12A	2025-07-31	√
36	Three-phase voltage drop change simulator	VDS-1120A	9536DA23A	2025-11-06	√
37	AMN	NSLK8126	8610CA12A	2025-07-31	√
38	Pulse limiter	CFL9026	8611CA12A	2025-07-31	√
39	receiver	ESR7	9618-6DA23A	2025-12-08	√
40	Reception Antenna	VULB9160	8616CA12A	2025-08-03	√
41	Amplifier	310N	8612CA12A	2025-07-31	√
42	Coupled decoupling network	CDN M016	8620CA12A	2025-07-31	√

TEST REPORT END

立章
建章